



# ISOIL

## I N D U S T R I A

### TECHNICAL DESCRIPTION USER MANUAL



### Mbus Protocol IFX-M4-04



## Table of contents

1. Reading of integral and moment parameters.....	3
Energy .....	4
Volume (or mass) .....	4
Power .....	5
Flow .....	5
Temperature .....	5
Pressure.....	5
Current date/time .....	5
Error codes.....	6
Power supply duration .....	6
Normal working time .....	6
Additional control sum (CRC-16).....	6
2. Readout of hours and days archive.....	7
Energy .....	8
Volume (or mass) .....	8
Temperature (average) .....	9
Pressure (average).....	9
Date and time of records .....	9
Error codes.....	9
Power supply duration .....	10
Normal working time .....	10
Additional control sum (CRC-16).....	10
Duration of errors .....	10
3. Secondary addressing .....	11
4. Reading the relay output parameters.....	11
5. Setting the relay output parameters .....	12
6. Reading of meter configuration .....	13

# 1. Reading of integral and moment parameters

First is SND\_NKE / E5 negotiation is performed. Master sends to the meter:

0	1	2	3	4
10h	40h	A	CS	16h

Answer of the meter:

0
E5h

A – M-bus primary address

CS – control sum

Then the selection of integral and moment parameters is performed. Master sends to the meter:

0	1	2	3	4	5	6	7	8	9
68h	04h	04h	68h	53h	A	50h	00h	CS	16h

Answer of the meter:

0
E5h

Then the query for data is performed. Master sends to the meter:

0	1	2	3	4
10h	5B/7B	A	CS	16

Answer of the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	L	L	68h	08h	A	72h	Nr <sub>0</sub>	Nr <sub>1</sub>	Nr <sub>2</sub>	Nr <sub>3</sub>	34h	2Ch	05h	04h

15	16	17	18	19-(n-2)		n-1	n
Acc	00h	00h	00h	Integral and moment parameters block		CS	16h

7...10 bytes: „Nr<sub>0</sub>... Nr<sub>3</sub>” – Serial number of meter,

11, 12 bytes: „34h,2Ch” – Manufacturer code (AXI)

13 byte: „05h” – Number of M-bus protocol version (3)

14 byte: „04h” – Measured medium („Heat”)

In the block of integral moment parameters can be following parameters (depending on configuration of the meter):

1. **Energy (total)** (except scheme F1 and F2).
2. **Energy 1** (only for schemes U1L, U2L, A, AC, A1, A1C, A2, A4, U1A3 and U2A3).
3. **Energy 2** (only for schemes U1L, U2L, A, AC, A1, A1C, A2, A4, U1A3 and U2A3).
4. **Volume (or mass) 1.**
5. **Volume (or mass) 2** (only for schemes U1F, U2F, A, AC, A1, A1C, A2, A4, A5, U1A3, U2A3 and F2).

6. **Volume (or mass) -2** (only for schemes A, AC, A1, A1C, when algorithm 3 is selected).
7. **Volume (or mass) 3** (when flow input 3 is active).
8. **Volume (or mass) 4** (when flow input 4 is active).
9. **Power** (except schemes F1 and F2).
10. **Flow 1**
11. **Flow 2** (only for schemes U1F, U2F, A, AC, A1, A1C, A2, A4, A5, U1A3, U2A3 and F2).
12. **Flow 3** (when flow input 3 is active).
13. **Flow 4** (when flow input 4 is active).
14. **Temperature 1** (when temperature input 1 is active).
15. **Temperature 2** (when temperature input 2 is active).
16. **Temperature 3** (when temperature input 3 is active).
17. **Temperature 4 (cold water temperature)** (only for schemes AC, A1C, A3, U1A3, U2A3).
18. **Pressure 1** (when pressure input 1 is active).
19. **Pressure 2** (when pressure input 2 is active).

Also, independently of configuration, following parameters are in the block:

1. **Current date/time** of the meter
2. **Error codes**
3. **Power supply duration**
4. **Normal working time**
5. **Additional control sum** (CRC-16)

## Coding of parameters

### Energy

Parameter	DIF	VIF								Data
		0,1 MWh	0,1 GJ	0,01 MWh	0,01 GJ	0,001 MWh	0,001 GJ	0,0001 MWh	0,0001 GJ	
Energy (total)	04	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)
Energy 1	84 40	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)
Energy 2	84 80 40	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)

### Volume (or mass)

Parameter	DIF	VIF								Data
		1 m <sup>3</sup>	1 t	0,1 m <sup>3</sup>	0,1 t	0,01 m <sup>3</sup>	0,01 t	0,001 m <sup>3</sup>	0,001 t	
Volume (mass) 1	04	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 2	84 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 3	84 80 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 4	84 C0 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) -2	84 80 80 40	16	96	15	95	14	94	13	93	4 bytes (long)

## Power

Parameter	DIF	VIF	Data
Power	05	2E	4 bytes (float) kW

## Flow

Parameter	DIF	VIF (m <sup>3</sup> /h)	VIF (t/h)	Data
Flow 1	05	3E	3E	4 bytes (float)
Flow 2	85 40	3E	3E	4 bytes (float)
Flow 3	85 80 40	3E	3E	4 bytes (float)
Flow 4	85 C0 40	3E	3E	4 bytes (float)

## Temperature

Parametras	DIF	VIF	Data
Temperature 1	02	59	2 bytes (word), 0,01°C
Temperature 2	02	5D	2 bytes (word), 0,01°C
Temperature 3	82 40	59	2 bytes (word), 0,01°C
Temperature 4 (const.)	82 40	65	2 bytes (word), 0,01°C

## Pressure

Parametras	DIF	VIF	Data
Pressure 1	03	68	3 bytes (word) 0,1 kPa
Pressure 2	83 40	68	3 bytes (word) 0,1 kPa

## Current date/time

Parameter	DIF	VIF	Data
Date/time	44	6D	4 bytes (date/time format)

## Format of date/time is following:

Bytes																															
3				2				1				0																			
Bits																															
31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
Year <sub>1</sub>				Month				Year <sub>0</sub>				Day				0	0	0	Hour				0	0	Minutes						

Minutes - <0 to 59>

Hour - <0 to 23>

Day - <1 to 31>

Month - <1 to 12>

Year=Year<sub>1</sub>|Year<sub>0</sub> (Year<sub>0</sub> – low significant part, Year<sub>1</sub> – high significant part) <0 to 99>

## Error codes

Parameter	DIF	VIF	Er1 (2 bytes)		Er2 (4 bytes)			
Error code	06	FD 17	B1	B2	B3	B4	B5	B6

Format of error code **Er1 (Er1: FEDCBA)** is following:

Byte B2								Byte B1															
Bits																							
07	06	05	04	03	02	01	00	07	06	05	04	03	02	01	00								
Digits and bits (3 2 1 0) of error code																							
F				E				D				C				B				A			
0	3	2	1	3	2	1	2	2	1	0	2	1	0	2	1	0	2	1	0				

Format of error code **Er2 (Er2: EDCBA)** is following:

Byte B4								Byte B3							
Bits															
07	06	05	04	03	02	01	00	07	06	05	04	03	02	01	00
Digits of error code															
D				C				B				A			

Byte B6								Byte B5							
Bits															
15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
Digits of error code															
Not used												E			

## Power supply duration

Parameter	DIF	VIF	Data
Power supply duration	04	20	4 bytes (long integer, time in seconds)

## Normal working time

Parameter	DIF	VIF	Data
Normal working time	04	24	4 bytes (long integer, time in seconds)

## Additional control sum (CRC-16)

Parameter	DIF	VIF	Data
Additional control sum (CRC-16)	02	7F	2 bytes

## 2. Readout of hours and days archive

First is SND\_NKE / E5 negotiation is performed. Master sends to the meter:

0	1	2	3	4
10h	40h	A	CS	16h

Answer of the meter:

0
E5h

Selection of hours or days archive is performed. Master sends to the meter:

0	1	2	3	4	5	6	7	8	9
68h	04h	04h	68h	53h	A	50h	04h – for hours archive 03h – for days archive	CS	16h

Answer of the meter:

0
E5h

Then the query for data is performed. Master sends to the meter:

0	1	2	3	4
10h	5B/7B	A	CS	16

Answer of the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	L	L	68h	08h	A	72h	Nr <sub>0</sub>	Nr <sub>1</sub>	Nr <sub>2</sub>	Nr <sub>3</sub>	34h	2Ch	05h	04h
15	16	17	18	19-(n-2)							n-1	n		
Acc	00h	00h	00h	Hours/days archive record block							CS	16h		

The readout of the next record of the archive is performed by sending data query packet with changed 1<sup>st</sup> byte 5Bh/7Bh (toggling the most significant bit of the byte). Archive readout is performed from the newest records.

In the first block of hours and days archive can be following parameters (depending on meter configuration):

1. **Energy (total)** (except scheme F1 and F2).
2. **Energy 1** (only for schemes U1L, U2L, A, AC, A1, A1C, A2, A4, U1A3 and U2A3).
3. **Energy 2** (only for schemes U1L, U2L, A, AC, A1, A1C, A2, A4, U1A3 and U2A3).
4. **Volume (or mass) 1.**
5. **Volume (or mass) 2** (only for schemes U1F, U2F, A, AC, A1, A1C, A2, A4, A5, U1A3, U2A3 and F2).
6. **Volume (or mass) -2** (only for schemes A, AC, A1, A1C, when algorithm 3 is selected).
7. **Volume (or mass) 3** (when flow input 3 is active).
8. **Volume (or mass) 4** (when flow input 4 is active).
9. **Power** (except schemes F1 and F2).
10. **Temperature 1 (average)** (when temperature input 1 is active).
11. **Temperature 2 (average)** (when temperature input 2 is active).
12. **Temperature 3 (average)** (when temperature input 3 is active).
13. **Temperature 4 (average of cold water temperature)** (only for schemes AC, A1C, A3, U1A3, U2A3).

14. **Pressure 1 (average)** (when pressure input 1 is active).

15. **Pressure 2 (average)** (when pressure input 2 is active).

Also, independently of configuration, following parameters are in the block:

1. **Current date/time** of the meter
2. **Error codes**
3. **Power supply duration**
4. **Normal working time**
5. **Additional control sum** (CRC-16)

In second block can be following parameters (depending on meter configuration):

1. **Duration, when temperature difference  $(T1-T2) < (T1-T2)_{min}$ .**
2. **Duration, when flow  $q1 < q1_{min}$ .**
3. **Duration, when flow  $q2 < q2_{min}$ .**
4. **Duration, when flow  $q3 < q3_{min}$ .**
5. **Duration, when flow  $q4 < q4_{min}$ .**
6. **Duration, when flow  $q1 > q1_{max}$ .**
7. **Duration, when flow  $q2 > q2_{max}$ .**
8. **Duration, when flow  $q3 > q3_{max}$ .**
9. **Duration, when flow  $q4 > q4_{max}$ .**
10. **Duration of error of flow sensor 1**
11. **Duration of error of flow sensor 2**
12. **Duration of error of flow sensor 3**
13. **Duration of error of flow sensor 4**
14. **Additional control sum** (CRC-16)

## Coding of parameters

### Energy

Parameter	DIF	VIF								Data
		0,1 MWh	0,1 GJ	0,01 MWh	0,01 GJ	0,001 MWh	0,001 GJ	0,0001 MWh	0,0001 GJ	
Energy (total)	04	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)
Energy 1	84 40	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)
Energy 2	84 80 40	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)

### Volume (or mass)

Parameter	DIF	VIF								Data
		1 m <sup>3</sup>	1 t	0,1 m <sup>3</sup>	0,1 t	0,01 m <sup>3</sup>	0,01 t	0,001 m <sup>3</sup>	0,001 t	
Volume (mass) 1	04	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 2	84 40	16	96	15	95	14	94	13	93	4 bytes (long)



Volume (mass) 3	84 80 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 4	84 C0 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) -2	84 80 80 40	16	96	15	95	14	94	13	93	4 bytes (long)

### Temperature (average)

Parametras	DIF	VIF	Data
Temperature 1	02	59	2 bytes (word), 0,01°C
Temperature 2	02	5D	2 bytes (word), 0,01°C
Temperature 3	82 40	59	2 bytes (word), 0,01°C
Temperature 4 (const.)	82 40	65	2 bytes (word), 0,01°C

### Pressure (average)

Parametras	DIF	VIF	Data
Pressure 1	03	68	3 bytes (word) 0,1 kPa
Pressure 2	83 40	68	3 bytes (word) 0,1 kPa

### Date and time of records

Parameter	DIF	VIF	Data
Date/time	44	6D	4 bytes (date/time format)

Format of date/time is following:

Bytes																															
3				2				1				0																			
Bits																															
31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16	15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
Year <sub>1</sub>				Month				Year <sub>0</sub>				Day				0	0	0	Hour				0	0	Minutes						

Minutes - <0 to 59>

Hour - <0 to 23>

Day - <1 to 31>

Month - <1 to 12>

Year=Year<sub>1</sub>|Year<sub>0</sub> (Year<sub>0</sub> – low significant part, Year<sub>1</sub> – high significant part) <0 to 99>

### Error codes

Parameter	DIF	VIF	Er1 (2 bytes)				Er2 (4 bytes)			
Error code	06	FD 17	B1	B2	B3	B4	B5	B6		

Format of error code **Er1 (Er1: FEDCBA)** is following:

Byte B2								Byte B1							
Bits															
07	06	05	04	03	02	01	00	07	06	05	04	03	02	01	00
Digits and bits (3 2 1 0) of error code															
F	E			D			C			B			A		
0	3	2	1	3	2	1	2	1	0	2	1	0	2	1	0

Format of error code **Er2 (Er2: EDCBA)** is following:

Byte B4								Byte B3							
Bits															
07	06	05	04	03	02	01	00	07	06	05	04	03	02	01	00
Digits of error code															
D				C				B				A			

Byte B6								Byte B5							
Bits															
15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00
Digits of error code															
Not used												E			

### Power supply duration

Parameter	DIF	VIF	Data
Power supply duration	04	20	4 bytes (long integer, time in seconds)

### Normal working time

Parameter	DIF	VIF	Data
Normal working time	04	24	4 bytes (long integer, time in seconds)

### Additional control sum (CRC-16)

Parameter	DIF	VIF	Data
Additional control sum (CRC-16)	02	7F	2 bytes

### Duration of errors

Parameter	DIF	VIF	Data
Duration, when temperature difference $(T1-T2) < (T1-T2)_{min}$	04	74	4 bytes (long integer, time in seconds)
Duration, when flow $q1 < q1_{min}$	84 40	74	4 bytes (long integer, time in seconds)
Duration, when flow $q2 < q2_{min}$	84 80 40	74	4 bytes (long integer, time in seconds)
Duration, when flow $q3 < q3_{min}$	84 C0 40	74	4 bytes (long integer, time in seconds)
Duration, when flow $q4 < q4_{min}$	84 80 80 40	74	4 bytes (long integer, time in seconds)
Duration, when flow $q1 > q1_{max}$	84 C0 80 40	74	4 bytes (long integer, time in seconds)
Duration, when flow $q2 > q2_{max}$	84 80 C0 40	74	4 bytes (long integer, time in seconds)
Duration, when flow $q3 > q3_{max}$	84 C0 C0 40	74	4 bytes (long integer, time in seconds)
Duration, when flow $q4 > q4_{max}$	84 80 80 80 40	74	4 bytes (long integer, time in seconds)
Duration of error of flow sensor 1	84 C0 80 80 40	74	4 bytes (long integer, time in seconds)
Duration of error of flow sensor 2	84 80 C0 80 40	74	4 bytes (long integer, time in seconds)
Duration of error of flow sensor 3	84 C0 C0 80 40	74	4 bytes (long integer, time in seconds)
Duration of error of flow sensor 4	84 80 80 C0 40	74	4 bytes (long integer, time in seconds)

### 3. Secondary addressing

Meter supports secondary addressing. The address of secondary addressing is meter parameter "Serial number" (Nr), and most significant digit (7-th) of address splits meter in to 1 ... 7 sub-meters. Possible meter response telegrams, depending on the address code, secondary address type meter configuration code bits (B0. .. B7) and meter configuration, see on the table:

Adress	Transmitted data	Conditions
{Nr}	As primary addressing case (see chapter 1)	B0=1 (or all B0,B1...B7=0) (standard settings)
{1000000+Nr}	Transmitted parameters E <sub>1</sub> , V <sub>2</sub> (or M <sub>2</sub> ), q <sub>2</sub> , T <sub>3</sub> , p <sub>2</sub> , ton, td, coded as E, V(or M), q, T <sub>1</sub> , p, ton, td	B1=1 and 2 <sup>nd</sup> flow channel is on
{2000000+Nr}	Transmitted parameters E <sub>2</sub> , V <sub>3</sub> , q <sub>3</sub> , ton, coded as E, V, q, ton	B2=1 and 3 <sup>d</sup> flow channel is on
{3000000+Nr}	Transmitted parameters V <sub>4</sub> , q <sub>4</sub> , ton, coded as V, q, ton	B3=1 and 4 <sup>th</sup> flow channel is on
{4000000+Nr}	Days archive	B4=1
{5000000+Nr}	Hours archive	B5=1
{6000000+Nr}	Days archive from end of last month	B6=1
{7000000+Nr}	Hours archive from end of last month	B7=1

Here: E – energy  
 V – volume (M – mass)  
 q – flow  
 T – temperature  
 p – pressure  
 ton – power supply duration  
 td– normal working time  
 1...4 – number of channel

### 4. Reading the relay output parameters

First is SND\_NKE / E5 negotiation is performed. Master sends to the meter:

0	1	2	3	4
10h	40h	A	CS	16h

Answer of the meter:

0
E5h

Selection of relay output parameters is performed. Master sends to the meter:

0	1	2	3	4	5	6	7	8	9
68h	04h	04h	68h	53h	A	50h	05h	CS	16h

Answer of the meter:

0
E5h

Then the query for data is performed. Master sends to the meter:

0	1	2	3	4
10h	5B/7B	A	CS	16

Answer of the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	21h	21h	68h	08h	A	72h	Nr <sub>0</sub>	Nr <sub>1</sub>	Nr <sub>2</sub>	Nr <sub>3</sub>	34h	2Ch	04h	04h

15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
Acc	00h	00h	00h	0Fh	00h	RelP	00h	Max <sub>0</sub>	Max <sub>1</sub>	Max <sub>2</sub>	Max <sub>3</sub>	Min <sub>0</sub>	Min <sub>1</sub>	Min <sub>2</sub>	Min <sub>3</sub>

31	32	33	34	35	36	37	38
RegT <sub>0</sub>	RegT <sub>1</sub>	RegL <sub>0</sub>	RegL <sub>1</sub>	RegCS <sub>0</sub>	RegCS <sub>1</sub>	CS	16

Parameters:

Parameter	Description
RelP	Code of parameter for relay output
Max	Upper value limit of regulated parameter (float)
Min	Lower value limit of regulated parameter (float)
RegT	Integral constant for regulation time (integer, sec)
RegL	Regulated valve run time (integer, sec)
Reg CS	Control sum of parameters RelP...RegL

## 5. Setting the relay output parameters

Master sends following packet to the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	15h	15h	68h	53h	A	51h	0Fh	00h	RelP	00h	Max <sub>0</sub>	Max <sub>1</sub>	Max <sub>2</sub>	Max <sub>3</sub>

15	16	17	18	19	20	21	22	23	24	25	26
Min <sub>0</sub>	Min <sub>1</sub>	Min <sub>2</sub>	Min <sub>3</sub>	RegT <sub>0</sub>	RegT <sub>1</sub>	RegL <sub>0</sub>	RegL <sub>1</sub>	RegCS <sub>0</sub>	RegCS <sub>1</sub>	CS	16

Answer of the meter:

0
E5h

Parameters:

Parameter	Description
RelP	Code of parameter for relay output
Max	Upper value limit of regulated parameter (float)
Min	Lower value limit of regulated parameter (float)
RegT	Integral constant for regulation time (integer, sec)
RegL	Regulated valve run time (integer, sec)
Reg CS	Control sum of parameters RelP...RegL

## 6. Reading of meter configuration

First is SND\_NKE / E5 negotiation is performed. Master sends to the meter:

0	1	2	3	4
10h	40h	A	CS	16h

Answer of the meter:

0
E5h

Then the selection of configuration parameters is performed. Master sends to the meter:

0	1	2	3	4	5	6	7	n-1	n
68h	04h	04h	68h	53h	A	50h	06h	CS	16h

Answer of the meter:

0
E5h

Then the query for data is performed. Master sends to the meter:

0	1	2	3	4
10h	5B/7B	A	CS	16

Answer of the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	L	L	68h	08h	A	72h	Nr <sub>0</sub>	Nr <sub>1</sub>	Nr <sub>2</sub>	Nr <sub>3</sub>	34h	2Ch	05h	04h

15	16	17	18	19	20	21-(n-2)	n-1	n
Acc	00h	00h	00h	0Fh	01h	Configuration of the meter	CS	16

Coding of configuration of the meter:

Offset in bytes	Parameter (format)
0	Nr <sub>0</sub>
1	Nr <sub>1</sub>
2	Nr <sub>2</sub>
3	Nr <sub>3</sub>
4	Nr1 <sub>0</sub>
5	Nr1 <sub>1</sub>
6	Nr1 <sub>2</sub>
7	Nr1 <sub>3</sub>
8	Nr2 <sub>0</sub>
9	Nr2 <sub>1</sub>
10	Nr2 <sub>2</sub>
11	Nr2 <sub>3</sub>
12	ANr <sub>0</sub>
13	ANr <sub>1</sub>
14	ANr <sub>2</sub>
15	ANr <sub>3</sub>
16	BatData <sub>0</sub>
17	BatData <sub>1</sub>
18	BatData <sub>02</sub>
19	BatData <sub>03</sub>
20	ModifAlg

  

Serial number of meter Nr (Unsigned integer)																									
Serial number of 1-st flow sensor Nr1 (Unsigned integer)																									
Serial number of 2-nd flow sensor Nr2 (Unsigned integer)																									
Customer number (Unsigned integer)																									
Battery change date (Unsigned integer, seconds since 2004.01.01 00:00)																									
Code of scheme and code of algorithm:																									
<table border="1"> <tr> <th colspan="8">Bits</th> </tr> <tr> <td>7</td> <td>6</td> <td>5</td> <td>4</td> <td>3</td> <td>2</td> <td>1</td> <td>0</td> </tr> <tr> <td colspan="6">Code of scheme: 0x00 – U1</td> <td colspan="2">Code of algorithm</td> </tr> </table>		Bits								7	6	5	4	3	2	1	0	Code of scheme: 0x00 – U1						Code of algorithm	
Bits																									
7	6	5	4	3	2	1	0																		
Code of scheme: 0x00 – U1						Code of algorithm																			

		0x01 – U2 0x03 – U1F 0x04 – U2F 0x05 – U1L 0x06 – U2L 0x07 – U3 0x08 – A 0x09 – A1 0x0A – A1C 0x0B – A2 0x0C – A3 0x0D – A4 0x0E – A5 0x0F – U1A3 0x10 – U2A3 0x11 – F1 0x12 – F2																											
21	TermoTipai	Temperature sensors types and status: <table border="1"> <thead> <tr> <th colspan="8">Bits</th> </tr> <tr> <th>7</th> <th>6</th> <th>5</th> <th colspan="2">4</th> <th>3</th> <th>2</th> <th>1</th> <th>0</th> </tr> </thead> <tbody> <tr> <td colspan="3">Not used</td> <td colspan="2">T3 activation</td> <td>T2 activation</td> <td>T1 activation</td> <td colspan="2">Types: 0 – Pt500 1 – Pt1000 2 – 500Π 3 – 1000Π</td> </tr> </tbody> </table>	Bits								7	6	5	4		3	2	1	0	Not used			T3 activation		T2 activation	T1 activation	Types: 0 – Pt500 1 – Pt1000 2 – 500Π 3 – 1000Π		
Bits																													
7	6	5	4		3	2	1	0																					
Not used			T3 activation		T2 activation	T1 activation	Types: 0 – Pt500 1 – Pt1000 2 – 500Π 3 – 1000Π																						
22	DTipas3	Type of flow input 3: <table border="1"> <thead> <tr> <th colspan="8">Bitai</th> </tr> <tr> <th>7</th> <th>6</th> <th>5</th> <th>4</th> <th>3</th> <th colspan="2">2</th> <th>1</th> <th>0</th> </tr> </thead> <tbody> <tr> <td colspan="5">Not used</td> <td colspan="2">Units: 0 – m<sup>3</sup> 1 – t</td> <td colspan="2">Type: 0 – Off 1 – S 2 – E 3 – L</td> </tr> </tbody> </table>	Bitai								7	6	5	4	3	2		1	0	Not used					Units: 0 – m <sup>3</sup> 1 – t		Type: 0 – Off 1 – S 2 – E 3 – L		
Bitai																													
7	6	5	4	3	2		1	0																					
Not used					Units: 0 – m <sup>3</sup> 1 – t		Type: 0 – Off 1 – S 2 – E 3 – L																						
23	Not used																												
24	Filtras3	Minimal pulse period of flow input 3 (integer, msec)																											
25	DTipas4	Type of flow input 4: <table border="1"> <thead> <tr> <th colspan="8">Bitai</th> </tr> <tr> <th>7</th> <th>6</th> <th>5</th> <th>4</th> <th>3</th> <th colspan="2">2</th> <th>1</th> <th>0</th> </tr> </thead> <tbody> <tr> <td colspan="5">Not used</td> <td colspan="2">Units: 0 – m<sup>3</sup> 1 – t</td> <td colspan="2">Type: 0 – Off 1 – S 2 – E 3 – L</td> </tr> </tbody> </table>	Bitai								7	6	5	4	3	2		1	0	Not used					Units: 0 – m <sup>3</sup> 1 – t		Type: 0 – Off 1 – S 2 – E 3 – L		
Bitai																													
7	6	5	4	3	2		1	0																					
Not used					Units: 0 – m <sup>3</sup> 1 – t		Type: 0 – Off 1 – S 2 – E 3 – L																						
26	Not used																												
27	DTipas4	Minimal pulse period of flow input 4 (integer, msec)																											
28	DIMP3 <sub>0</sub>	Pulse value of flow input 3 (float, m <sup>3</sup> /pulse)																											
29	DIMP3 <sub>1</sub>																												
30	DIMP3 <sub>2</sub>																												
31	DIMP3 <sub>3</sub>																												
32	DIMP3 <sub>0</sub>																												
33	DIMP4 <sub>1</sub>	Pulse value of flow input 4 (float, m <sup>3</sup> /pulse)																											
34	DIMP4 <sub>2</sub>																												
35	DIMP4 <sub>3</sub>																												
36	QMIN1 <sub>0</sub>		Min flow value of flow sensor 1 (float, m <sup>3</sup> /h)																										

37	QMIN1 <sub>1</sub>																																																																																		
38	QMIN1 <sub>2</sub>																																																																																		
39	QMIN1 <sub>3</sub>																																																																																		
40	QMIN2 <sub>0</sub>	Min flow value of flow sensor 2 (float, m <sup>3</sup> /h)																																																																																	
41	QMIN2 <sub>1</sub>																																																																																		
42	QMIN2 <sub>2</sub>																																																																																		
43	QMIN2 <sub>3</sub>																																																																																		
44	QMIN3 <sub>0</sub>	Min flow value of flow input 3 (float, m <sup>3</sup> /h)																																																																																	
45	QMIN3 <sub>1</sub>																																																																																		
46	QMIN3 <sub>2</sub>																																																																																		
47	QMIN3 <sub>3</sub>																																																																																		
48	QMIN4 <sub>0</sub>	Min flow value of flow input 4 (float, m <sup>3</sup> /h)																																																																																	
49	QMIN4 <sub>1</sub>																																																																																		
50	QMIN4 <sub>2</sub>																																																																																		
51	QMIN4 <sub>3</sub>																																																																																		
52	QMAX1 <sub>0</sub>	Max flow value of flow sensor 1 (float, m <sup>3</sup> /h)																																																																																	
53	QMAX1 <sub>1</sub>																																																																																		
54	QMAX1 <sub>2</sub>																																																																																		
55	QMAX1 <sub>3</sub>																																																																																		
56	QMAX2 <sub>0</sub>	Max flow value of flow sensor 2 (float, m <sup>3</sup> /h)																																																																																	
57	QMAX2 <sub>1</sub>																																																																																		
58	QMAX2 <sub>2</sub>																																																																																		
59	QMAX2 <sub>3</sub>																																																																																		
60	QMAX3 <sub>0</sub>	Max flow value of flow input 3 (float, m <sup>3</sup> /h)																																																																																	
61	QMAX3 <sub>1</sub>																																																																																		
62	QMAX3 <sub>2</sub>																																																																																		
63	QMAX3 <sub>3</sub>																																																																																		
64	QMAX4 <sub>0</sub>	Max flow value of flow input 4 (float, m <sup>3</sup> /h)																																																																																	
65	QMAX4 <sub>1</sub>																																																																																		
66	QMAX4 <sub>2</sub>																																																																																		
67	QMAX4 <sub>3</sub>																																																																																		
68	KTEMP <sub>0</sub>	Cold water temperature constant (integer, 0,01 °C)																																																																																	
69	KTEMP <sub>1</sub>																																																																																		
70	(T1-T2) <sub>min0</sub>	Min temperature difference T1-T2 (integer, 0,01 °C)																																																																																	
71	(T1-T2) <sub>min1</sub>																																																																																		
72	SMIN <sub>0</sub>	Min value of pressure sensors (integer, 0,1 kPa)																																																																																	
73	SMIN <sub>1</sub>																																																																																		
74	SMAX <sub>0</sub>	Max value of pressure sensors (integer, 0,1 kPa)																																																																																	
75	SMAX <sub>1</sub>																																																																																		
76	SENT <sub>0</sub>	Value of pressure for calculations (integer, 0,1 kPa)																																																																																	
77	SENT <sub>1</sub>																																																																																		
78	SIRIB	Limits of current of pressure sensors inputs: 0x00 – 0-20 mA 0x01 – 4-20 mA 0x02 – 0-4 mA																																																																																	
79	MBusAddr	M-Bus adresas																																																																																	
80	UARTSpeed1	Boud rate of wire interface	<table border="1"> <thead> <tr><th colspan="8">Bits</th></tr> <tr><th>7</th><th>6</th><th>5</th><th>4</th><th>3</th><th>2</th><th>1</th><th>0</th></tr> </thead> <tbody> <tr><td>0 – None parity</td><td colspan="7">0x00 – 300 bps</td></tr> <tr><td>1 – Even parity</td><td colspan="7">0x01 – 600 bps</td></tr> <tr><td></td><td colspan="7">0x02 – 1200 bps</td></tr> <tr><td></td><td colspan="7">0x03 – 2400 bps</td></tr> <tr><td></td><td colspan="7">0x04 – 4800 bps</td></tr> <tr><td></td><td colspan="7">0x05 – 9600 bps</td></tr> <tr><td></td><td colspan="7">0x06 – 19200 bps</td></tr> <tr><td></td><td colspan="7">0x07 – 38400 bps</td></tr> </tbody> </table>	Bits								7	6	5	4	3	2	1	0	0 – None parity	0x00 – 300 bps							1 – Even parity	0x01 – 600 bps								0x02 – 1200 bps								0x03 – 2400 bps								0x04 – 4800 bps								0x05 – 9600 bps								0x06 – 19200 bps								0x07 – 38400 bps						
Bits																																																																																			
7	6	5	4	3	2	1	0																																																																												
0 – None parity	0x00 – 300 bps																																																																																		
1 – Even parity	0x01 – 600 bps																																																																																		
	0x02 – 1200 bps																																																																																		
	0x03 – 2400 bps																																																																																		
	0x04 – 4800 bps																																																																																		
	0x05 – 9600 bps																																																																																		
	0x06 – 19200 bps																																																																																		
	0x07 – 38400 bps																																																																																		
81	UARTSpeed2	Boud rate of optical interface																																																																																	

82	PPULS1	Parameter for 1 <sup>st</sup> pulse/frequency output	0x00 – Off 0x01 – Energy (total) 0x02 – Energy 1 0x03 – Energy 2 0x04 – Volume V1 0x05 – Volume V2 0x06 – Volume –V2 0x07 – Volume V3 0x08 – Volume V4 0x09 – Mass M1 0x0A – Mass M2 0x0B – Mass –M2 0x0C – Mass M3 0x0D – Power 0x0E – Flow q1 0x0F – Flow q2 0x10 – Flow q3 0x11 – Flow q4 0x12 – Temperature T1 0x13 – Temperature T2 0x14 – Temperature (T1-T2) 0x15 – Temperature T3 0x16 – Presse p1 0x17 – Presse p2																														
83	PPULS2	Parameter for 2 <sup>nd</sup> pulse/frequency output	0x00 – Off 0x01 – Energy (total) 0x02 – Energy 1 0x03 – Energy 2 0x04 – Volume V1 0x05 – Volume V2 0x06 – Volume –V2 0x07 – Volume V3 0x08 – Volume V4 0x09 – Mass M1 0x0A – Mass M2 0x0B – Mass –M2 0x0C – Mass M3 0x0D – Power 0x0E – Flow q1 0x0F – Flow q2 0x10 – Flow q3 0x11 – Flow q4 0x12 – Temperature T1 0x13 – Temperature T2 0x14 – Temperature (T1-T2) 0x15 – Temperature T3 0x16 – Presse p1 0x17 – Presse p2																														
84	PKALBA	Report printing language and interface: <table border="1" data-bbox="695 1010 1353 1240"> <tr> <th colspan="8">Bits</th> </tr> <tr> <th colspan="4">7</th> <th>6</th> <th>5</th> <th>4</th> <th>3</th> <th>2</th> <th>1</th> <th>0</th> </tr> <tr> <td colspan="4">Interface for printig: 0 – wire 1 – optical</td> <td colspan="7">Language: 0x00 – English 0x01 – Russian 0x02 – Lithuanian</td> </tr> </table>		Bits								7				6	5	4	3	2	1	0	Interface for printig: 0 – wire 1 – optical				Language: 0x00 – English 0x01 – Russian 0x02 – Lithuanian						
Bits																																	
7				6	5	4	3	2	1	0																							
Interface for printig: 0 – wire 1 – optical				Language: 0x00 – English 0x01 – Russian 0x02 – Lithuanian																													
85	MATVNT	Units: <table border="1" data-bbox="695 1274 1386 1469"> <tr> <th colspan="10">Bits</th> </tr> <tr> <th>7</th> <th>6</th> <th>5</th> <th>4</th> <th colspan="2">3</th> <th colspan="2">2</th> <th>1</th> <th>0</th> </tr> <tr> <td colspan="4">Not used</td> <td colspan="2">V2 units: 0 – m<sup>3</sup> 1 – t</td> <td colspan="2">V1 units: 0 – m<sup>3</sup> 1 – t</td> <td colspan="2">Energy: 0x00 – MWh 0x01 – Gcal 0x02 – GJ</td> </tr> </table>		Bits										7	6	5	4	3		2		1	0	Not used				V2 units: 0 – m <sup>3</sup> 1 – t		V1 units: 0 – m <sup>3</sup> 1 – t		Energy: 0x00 – MWh 0x01 – Gcal 0x02 – GJ	
Bits																																	
7	6	5	4	3		2		1	0																								
Not used				V2 units: 0 – m <sup>3</sup> 1 – t		V1 units: 0 – m <sup>3</sup> 1 – t		Energy: 0x00 – MWh 0x01 – Gcal 0x02 – GJ																									



# ISOIL INDUSTRIA S.p.A.

HEAD OFFICE	SERVICE
Via Fratelli Gracchi, 27 20092 Cinisello Balsamo (MI) Tel +39 02 66027.1 Fax 039 026123202 sales@isoil.it	isomagservice@isoil.it

If you want to find the complete list of our distributors access at the following link:

[http://isoil.com/u\\_vendita.asp](http://isoil.com/u_vendita.asp)

**BEFORE** returning any material, please contact our SERVICE at the e-mail address:

[isomagservice@isoil.com](mailto:isomagservice@isoil.com)



Due to the constant technical development of its products, the manufacturer reserves the right to make changes and/or modify the information contained in this document without n

COMPANY WITH  
QUALITY SYSTEM  
CERTIFIED BY DNV GL  
= ISO 9001 =

**ISOIL**   
I N D U S T R I A  
*The solutions that count*